



**TO:** Plan Holders

**FROM:** Nathan Simons, Community Development Coordinator

**DATE:** Thursday, April 8th, 2021

**RE:** Laurelville Flood & Drainage Facility Improvements

### **ADDENDUM #1**

This addendum supplements and amends the specifications and shall become part of the contract documents. The contractor shall acknowledge receipt of this addendum on the Bid Form and incorporate the information herein contained in the preparation of his/her proposal.

1. The engineer issued the following exception:
  - In lieu of 301 and 448 pavements, 8" of ODOT Item 452 Concrete will be acceptable as an alternative for roadway pavement

All other terms and conditions remain the same.

**END OF ADDENDUM #1**