



TO: Plan Holders

FROM: Nathan Simons, Community Development Coordinator

DATE: Thursday, May 07, 2021

RE: Athens County C.I. Chauncey Ohio Sanitary Sewer Improvements

ADDENDUM #1

This addendum supplements and amends the specifications and shall become part of the contract documents. The contractor shall acknowledge receipt of this addendum on the Bid Form and incorporate the information herein contained in the preparation of his/her proposal.

1. The engineer has issued new bidding directives for the Chauncey C.I. please see all attachments included
2. Pickering & Associates added note 4 to the bottom of C100 and rev clouded it for this addendum.
3. Pickering & Associates updated Bid Unit Prices form to include lateral reconnections. (See notes attached)

All other terms and conditions remain the same.

END OF ADDENDUM #1



NOTES:

Contractor Inquiry The bid sheet for the above referenced project does not include sewer laterals for reconnection to approximately 14 residence. Is the contractor to assume this is calculated with 10" conduit. Please advise.

Response The bid unit price sheet has been updated to include a line item for lateral reconnection. The assumption is that the 14 lateral connections are 4" diameter connections. The only connection is on a drop connection at a manhole and is listed on drawing C000 as an alternate.







MASTER PLAN

 SCALE: 1"=50'

- NOTES:
1. PROJECT EXTENTS RUN FROM MH1 TO MH4.
 2. CONTRACTOR TO SUPPLY BYPASS PUMPING SCHEDULE AND PLAN TO ENGINEER FOR REVIEW.
 3. DESIGN FLOW FOR BYPASS PUMPING: 200,000gpd
 4. THIS PROJECT SHALL ASSUME 14 LATERALS ASSOCIATED WITH RECORDS OF INSTALLATION SHALL BE INSTALLED. RECORDS OF THESE REPAIRS SHALL BE MAINTAINED AS REQUIRED TO ACCOMMODATE OPEN TRENCHING OF MAINLINE.

| | | |
|---|---|--------------------------------|
|  | Drawing Description ATHENS COUNTY COMMISSIONERS CHAUNCEY, OHIO VILLAGE OF CHAUNCEY, C.I. (SEWER IMPROVEMENTS) MASTER PLAN | |
| | Project: 2202052 Designed By: JRB Drawn By: JRB Checked By: JRB Scale: AS NOTED Plot Date: 05/18/21 Revision: 1 | Drawing Number: C100 |

| Rev. | Description | By | Date |
|------|-----------------------------|-----|----------|
| 1 | ISSUED FOR BID/CONSTRUCTION | JRB | 05/18/21 |
| 0 | ISSUED FOR BID/CONSTRUCTION | JRB | 04/07/21 |



PICKERING ASSOCIATES
 Architects • Engineers • Surveyors
 11283 Emerson Avenue
 Parkersburg, WV 26104
 Phone: (304) 464-5305
 Fax: (304) 464-4428



Bid Unit Prices
REV 1 – 05/20/21

The following items are requested to be designated as Unit Prices for bidding purposes.

• **Item Information:**

- ODOT Item No. 202E23000 – Pavement Removed Price per SY: \$ _____
- ODOT Item No. 203E10000 – Excavation Price per CY: \$ _____
- ODOT Item No. 304E20000 – Aggregate Base Price per CY: \$ _____
- ODOT Item No. 441E50000 – Asphalt Concrete Surface Course Price per CY: \$ _____
- ODOT Item No. 301E46000 – Asphalt Concrete Base, PG64-22 Price per CY: \$ _____
- ODOT Type 2 Structural Backfill / Pipe Bedding Price per CY: \$ _____
- ODOT 10" Conduit, Type B (10" SDR 26 Gravity Sewer): Price per FT: \$ _____
- Manhole Rehabilitation: Price per Vert. Ft. \$ _____
- Lateral Reconnection (4"): Price Each: \$ _____
 - Added via Addendum (5/20)